

City of Shakopee – Shakopee Fire Department

Staff Review

Case Number: 17044

From: Tom Pitschneider, Fire Marshal

Date: 08/04/2017

Request: Interim Use Permit – Trailer Storage

Staff Recommendation: **Approve with Changes/Conditions Listed**

Project Conditions

1. Trailers to be parked so the maximum area is 100-feet by 250-feet per area. A minimum of 10-feet shall be maintained between each area.

