Fence Plan for SPU East Substation on Reliakor Second Addition Site

There will be an 8-foot-tall, chain link perimeter fence around the substation facilities as shown on drawing 334142-200.A.

The fence material will be galvanized steel.

The fence will not have barbed wire at the top.