

**City of Shakopee**

485 Gorman Street  
Shakopee, MN 55379  
952-233-9396  
www.shakopeemn.gov

**PERMIT****SHAKOPEE**Revision 7/2/18  
**Permit Type:****Permit Number:****Building****SH088742**

\* 0 8 8 7 4 2 \*

**Date Issued:****09/20/2017****Site Address: 1806 Co Rd 14****Lot:** 000 **Block:** 000 **Addition:****PID:** 27-932003-0**Use:****Description:****Sub Type:** Garages/Accessory Bldgs.**Construction Type:** V-B**Work Type:** New**Description:** 36X56 pole barn revision 1/12/18**Census Code:** -**Occupancy:** U-1**Zoning:****Bldg Sq Ft:** 2,016**Bsmt Sq Ft:** 0

**Comments:** Smooth or corrugated metal siding is not permitted. Exterior rated and finished (painted or stained) wood siding is permitted. Height of building must not exceed 15' at midpoint of roof (a change of original plan was required to reduce height). Building must meet 5' setback from side lot line.

**Fee Summary:****Valuation:** 32,327.00**Description**

BL-Building Application Plan Review Fee

**Amount**

(\$156.94)

**Revenue Code**

0332-4259

Electronic Processing Fee

\$32.33

0331.4299

MN League valuation (BP)

\$300.62

0333-4251

Plan Review (PC)

\$195.40

0332.4259

Surcharge - Based on Valuation

\$16.16

0913.2060 (BS)

**Total:****\$387.57****Contractor:****Owner:**

- Applicant -

BRADLEY C REILAND

1806 CO RD 14

SHAKOPEE MN 55379

This permit becomes null and void if work or construction authorized is not commenced within 180 days, or if construction is suspended or abandoned for a period of 180 days at any time after the work is commence.

Applicant/Permitee: Signature

Issued By: Signature