



SHAKOPEE PUBLIC UTILITIES COMMISSION

“Lighting the Way - Yesterday, Today and Beyond”

MEMORANDUM

TO: Shakopee Community Development Department

FROM: Joseph D. Adams, Planning and Engineering Director

SUBJECT: STAFF REVIEW RECORD COMMENTS for:
CUP for Resonate Community Church – 1760 4th Ave E

CASE NO: **SH-100118**

DATE: 4/28/2020

COMMENTS:

The existing building (the former Knights of Columbus Hall) shall be connected to the public water system. The existing well shall be disconnected from the interior plumbing system. The Knights of Columbus have paid the Water Capacity Charge that was based on the number of SAC units assigned by the Met Council. If the Met Council assigns additional SAC units, the applicant will receive credit for the amount already paid by the Knights of Columbus. Applicant shall contact Shakopee Public Utilities to receive all the steps to finalize the connection to the public water system.